

Declaration of Conformity

FAFNIR GmbH
Schnackenburgallee 149 c
22525 Hamburg
Germany

declares as manufacturer under sole responsibility that the

Automatic Tank Gauge **VISY-X**

with the components

VISY-Stick ...	Gauge Sensor
VISY-Command ... GUI / VISY-Command ... Web	(Evaluation Unit with) Indicator Device
VISY-ViewTouch / SECON-Lev...	Indicator Device

complies with the European standard

EN 13352:2012	Specification for the performance of automatic tank contents gauges
----------------------	--

The gauge sensor of the automatic tank gauge is classified as

Level and Temperature Measurement Class	A
Temperature Category	O
Water Detection Performance	W

The indicator device of the automatic tank gauge is classified as

Level and Temperature Measurement Class	A
Temperature Category	I

Hamburg, 2020-05-07
Place, Date



Managing Director: René Albrecht